



6'-0" HIGH WALL - METAL PANELS ON 3 5/8" X 20 GA METAL STUDS @ 15" OC W/ 1" ST. PIPE COLUMNS @ 6'-0" OC

Metal Sides taking white

13.0 @ 7.7" = 10'-0"
12.1 @ 10" = 12'-0"
* VERIFY HEIGHT - RISER NOT TO EXCEED 7 3/4"

5 x 5 ST. POST & CONC. FLOORING, TYPICAL - SEE DETAIL

BATH ROOM NOTES

- REMOVE SHOWER & PLATFORM
- NEW 6 X 8 SPANISH BLE ALL FLOOR
- RELOCATE SINK
- NEW SS CRAB BAR TO COMPLY W/ GA. HANDICAP CODE
- NEW 36" WBE DOOR TO COMPLY W/ GA. HANDICAP CODE

FIRE RATED CEILING NOTES

- HATCHED AREA TO RECEIVE 1 HOUR FIRE RATED LAY-IN CEILING - ADJUST LIGHT FIXTURES & HVAC DIFFUSERS AS NECESSARY TO COMPLY W/ FIRE RATING
- CROSS-HATCHED AREA TO RECEIVE ONE LAYER OF 5/8" FIRE RATED GYP. BOARD TO ACHIEVE A ONE HOUR FIRE RATING - RE-LOCATE CROWN MOULDING
- PERIMETER OF SHADED AREAS TO BE SEALED WITH FIRE RATED GYP. BOARD FOR 1 HOUR FIRE RATING AT INTERSECTION OF CEILING AND WALL

1st FLOOR PLAN

1/8" = 1'-0"

DRAWN	WCC
APPROVED	WCC
COMM. NO.	0102
DATE	JUN. 4, 2001
REVISIONS:	PERMITTING